

WATER NOTES:

1. All water mains shall be AWWA C900.
2. Water services shall be single 1" copper tubing.
3. Water line is to be constructed in accordance with the NBU Systems Connection & Construction Policy.
4. Water main shall have a minimum of 42 inches of cover, otherwise concrete encasement will be required.
5. Each unit in a duplex, triplex, fourplex, or condominium shall be provided with an individual water meter. A master meter can be considered for separate buildings, however, those buildings must be plumbed to allow separate meters for future consideration.
6. Contractor will keep the area on top of and around the water meter box free of all objects and debris.
7. Initial backfill of water lines shall be manufactured sand or pea gravel as per NBU Systems Connection & Construction Policy.
8. Secondary backfill of water lines shall generally consist of material removed from the trench and shall be free from brush, debris and trash or stones having any dimension larger than 6" inches at the largest dimension.
9. Hydrostatic testing from valve to valve.
10. No meter boxes to be set in driveways. Any meter boxes set in driveways will be relocated at contractor's and/or developer's expense.
11. Meter boxes must be set at the proposed grade. Any meter boxes that are not set at the final grade will be adjusted at contractor's and/or developer's expense.