


MATERIAL LIST:

- (A) SERVICE CLAMP REQUIRED ON ALL PLASTIC & ASBESTOS CEMENT PIPE AND ON ALL IRON PIPE 12" AND SMALLER.
- (B) 1 1/2" CORPORATION STOP - SERVICE PIPE OUTLET.
- (C) 1 1/2" SERVICE PIPE.
- (D) 1 1/2" COUPLING: SERVICE PIPE TO MALE I.P.T. (COMPRESSION FITTINGS)
- (E) 1 1/2" BALL VALVE.
- (F) 1 1/2" CLOSE NIPPLE, BRONZE I.P. THREAD.
- (G) 1 1/2" BRONZE TEE.
- (H) BRONZE BUSHING, 1 1/2" X 1", I.P. THREADS



DRAWN BY:
H Shadrock
APPROVED BY:

STANDARD DRAWING: **STANDARD INSTALL DETAIL FOR TWO
5/8", 3/4" & 1" METER**

UPDATED:
4-11-03

SCALE:
N.T.S.

SHEET:
1 OF 2

DRAWING NO.
201