

| NO. | NAME                                      | LENGTH |
|-----|---|--------|
| 1   | 6" COMPOUND METER                         | 24"*   |
| 2   | 6" FLANGED x PLAIN END                    | 12"    |
| 3   | 6" FLANGED COUPLING ADAPTER               | 5"     |
| 4   | NBU 6" GATE VALVE SQUARE NUT              | 10.5"  |
| 5   | 6" x 6" x 6" FLANGED TEE                  | 16"    |
| 6   | PROPERTY OWNER'S 6" GATE VALVE SQUARE NUT | 10.5"  |
| 7   | 6" FLANGED ELBOW 90°                      |        |
| 8   | 6" BYPASS GATE VALVE with HANDWHEEL       | 10.5"  |
| 9   | 6" BYPASS DUCTILE IRON PIPE               |        |
| 10  | 6" FLANGED SPOOL                          |        |

\*DIMENSIONS- SUBJECT TO CHANGE, CHECK WITH INSPECTOR

**NOTES:**

1. PIPE AND METER SIZE SHALL BE AS DETERMINED BY OWNER; APPROVAL BY NBU WATER SYSTEMS ENGINEERING. PLANS MUST BE PREPARED BY LICENSED ENGINEER IF INSTALLATION IN RIGHT-OF-WAY IS BY OTHER THAN NEW BRAUNFELS UTILITIES FORCES.
2. METER VAULT MUST BE BEHIND CURB AND/OR WALK AND OUT OF VEHICULAR TRAFFIC.
3. MAIN LINE AND BYPASS VALVES WILL BE RESILIENT SEAT TYPE WITH CORROSION RESISTANT FUSION BONDED EPOXY COATING INSIDE AND OUTSIDE, NON-RISING STEM. MAIN LINE VALVES SHALL HAVE SQUARE OPERATING NUTS. BYPASS VALVE WILL HAVE A HANDWHEEL. PROPERTY OWNER'S VALVE MUST BE LOCATED OUTSIDE OF THE NEW BRAUNFELS UTILITIES METER VAULT.
4. APPROVAL WILL BE NEEDED IF HEIGHT OF VAULT EXCEEDS 72", CALL NEW BRAUNFELS UTILITIES.
5. HATCH OPENING WILL BE 30" X 30".
6. IRON PIPE TAPPING SLEEVE IN STREET RIGHT-OF-WAY SHALL BE IMBEDDED IN GRANULAR MATERIALS AS REQUIRED BY SPECIFICATIONS; BACKFILL ABOVE GRANULAR BEDDING AS REQUIRED BY SPECIFICATIONS.
7. DOUBLE HARNESS MJ WITH TIE RODS. ALL OTHER FITTINGS INSIDE VAULT WILL BE FLANGED.
8. CONTACT NEW BRAUNFELS UTILITIES PRIOR TO INSTALLATION OF COMPOUND METERS FOR PROPER DOMESTIC DEMANDS.
9. NOTCHES WHERE PIPING GOES THROUGH VAULT SHALL BE FILLED WITH MORTAR.
10. THE TOP OF THE METER VAULT SHALL BE AT AN ELEVATION SUCH THAT THE SURROUNDING GROUND SLOPES AWAY FROM THE VAULT.



DRAWN BY:  
**H Shadrock**  
APPROVED BY:

STANDARD DRAWING:

**COMPOUND METER INSTALLATION 6" SIZE**

UPDATED:  
**4-23-03**

SCALE:  
**N.T.S.**

SHEET:  
**2 OF 2**

DRAWING NO.  
**206**