


NOTES:

1. HYDRANTS ARE NOT TO BE PLACED IN SIDEWALK AREAS. SEE NEW BRAUNFELS UTILITIES STANDARD SPECIFICATIONS FOR LOCATION OF HYDRANT.
2. FOR BURY DEPTHS GREATER THAN 5', ONE BARREL EXTENSION NOT EXCEEDING 2' IN LENGTH SHALL BE INSTALLED DIRECTLY BELOW THE FIRE HYDRANT.
3. CONCRETE BLOCKING WITH A MIN. 1 1/2 FT² BEARING AREA, CLASS A CONCRETE. DO NOT BLOCK DRAIN HOLES.
4. CRUSHED STONE OR GRAVEL SHALL BE PLACED AROUND THE BOTTOM OF THE HYDRANT FOR A RADIUS OF AT LEAST 12" AND EXTEND AT LEAST 12" ABOVE THE OUTLET. DO NOT BLOCK DRAIN HOLES.



DRAWN BY:
JD Amaro
APPROVED BY:

STANDARD DRAWING:

**FIRE HYDRANT INSTALLATION WITH
PRESSURE REDUCING VALVE**

UPDATED:
4-15-03

SCALE:
N.T.S.

SHEET:
1 OF 1

DRAWING NO.
241