


NOTES:

1. STANDARD LOCATIONS WITH NO SIDEWALK OR WHEN SIDEWALK IS NEXT TO CURB
2. END OF SERVICE PIPE TO BE 48" PAST PROPERTY LINE OR IF UNDERGROUND ELECTRIC IS PRESENT IN EASEMENT THEN SERVICE TO END 48" PAST ELECTRIC CONDUIT.



DRAWN BY:
H Shadrock
APPROVED BY:

STANDARD DRAWING:

WATER SERVICE CONNECTION DETAIL

UPDATED:
4-15-03

SCALE:
N.T.S.

SHEET:
1 OF 2

DRAWING NO.
245