

NOTES:

1. UTILITY CONTRACTOR INSTALLS WATER CONNECTION TO MAIN WATER PIPE, FITTINGS AND VALVES INCLUDING STOP VALVE, REFER TO INSTALLATION DETAILS FOR LOCATION OF STOP VALVES. ALL INSTALLATIONS SHALL BE MADE IN ACCORDANCE WITH INFORMATION SHOWN ON APPLICABLE STANDARD DRAWINGS AND WILL BE INSPECTED BY NEW BRAUNFELS UTILITIES (NBU) CONSTRUCTION INSPECTION PERSONNEL.
2. DEVELOPER'S CONTRACTOR TO INSTALL WATER LINES INCLUDING FITTINGS AND VALVES UP TO METER, INSTALL METER BOXES AND COVERS, ALL IN ACCORDANCE WITH INFORMATION ON APPLICABLE STANDARD DRAWING. A VENTED SPACER MAY BE USED TO ASSURE PROPER SPACING AND ALIGNMENT OF METER FITTINGS.
3. DEVELOPER AND/OR CUSTOMER IS RESPONSIBLE FOR METER BOX UNTIL METER IS INSTALLED AND IS CONNECTED. ANY MISSING OR DAMAGED PARTS SHALL BE REINSTALLED BY DEVELOPER/CUSTOMER WHO SHALL GUARANTEE, FOR A PERIOD OF ONE (1) YEAR FROM DATE OF ACCEPTANCE, THAT CONNECTIONS TO SYSTEMS ARE FREE FROM DEFECTS IN WORKMANSHIP OR MATERIALS. DEVELOPER/CUSTOMER ALSO HAS THE RESPONSIBILITY TO ASSURE THAT ALL VALVES AND STOPS, METER BOX AND REMAIN CLEAR OF SIDEWALKS AND OTHER OBSTRUCTIONS.
4. NEW BRAUNFELS UTILITIES (NBU) ACTIVITY IS LIMITED TO INSTALLATION OF THE WATER METER AND INSPECTION OF CONNECTIONS TO NBU'S WATER SYSTEMS. FOR MAINTENANCE PURPOSES, NBU'S RESPONSIBILITY ENDS AT THE CUSTOMER'S SIDE OF THE WATER METER.
5. NO METER BOX SHALL BE SET IN SIDEWALK AREA WITHOUT WRITTEN APPROVAL FROM THE WATER SYSTEMS ENGINEERING DEPARTMENT.



DRAWN BY:  
*H Shadrock*  
APPROVED BY:

STANDARD DRAWING:

**SINGLE WATER SERVICE CONNECTION DETAIL**

UPDATED:  
**4-15-03**

SCALE:  
**N.T.S.**

SHEET:  
**2 OF 2**

DRAWING NO.  
**245**