



GENERAL NOTES:

- EXTERIOR SURFACES OF EXPOSED AIR VENT PIPE AND D.I. SUPPORT PIPE SHALL BE PAINTED WITH RUST-OLEUM ACRYLIC 5225 (SAFETY BLUE), OR EQUAL, PER COATING MANUFACTURER INSTRUCTIONS PRIOR TO INSTALLATION.
- AIR VENT PIPE INSTALLATION SHALL BE AS NEAR AS PRACTICAL TO RIGHT-OF-WAY LINE.
- CONCRETE METER BOX PENETRATION SHALL BE CORE BIT DRILLED. VOID SHALL BE FILLED BY PRESS-SEAL GASKET CORP. PSX RESILIENT CONNECTOR MEETING ASTM C923 OR APPROVED EQUAL.
- 5' MIN. (UNDEVELOPED AREAS) 14" MAX. (DEVELOPED AREAS)



DRAWN BY:
JD Amaro
APPROVED BY:

STANDARD DRAWING:

**1" - 2" AIR RELEASE VALVE
INSTALLATION (TYPE 1)**

UPDATED:
4-15-03

SCALE:
N.T.S.

SHEET:
1 OF 1

DRAWING NO.
260