

GENERAL NOTES:

1. ON 10" AND LARGER TWO PIECE COMBINATION AIR VALVES, THE OUTLET PIPING OF THE SMALL VALVE SHALL BE VENTED WITHIN THE MANHOLE INTO THE SIDE OF THE LARGER VENT PIPE THAT GOES ABOVE GROUND.
2. AIR VENT PIPE 6" AND LARGER SHALL BE D.I. (CLASS 350 MIN.) PIPE FLANGE FITTINGS ORDERED SPECIAL WITH SHOP APPLIED COPPER INERTOL RUST INHIBITIVE PRIMER 621, OR EQUAL, IN LIEU OF COAL TAR. EXTERIOR SURFACES OF ALL EXPOSED PIPE SHALL BE PAINTED WITH RUST-OLEUM ACRYLIC 5225 (SAFETY BLUE), OR EQUAL PER COATING MANUFACTURER'S INSTRUCTIONS PRIOR TO INSTALLATION.
3. SEALANT SHALL BE 1 1/4" FLEXIBLE BUTYL RESIN SEALANT CS-102 AS MANUFACTURED BY CONCRETE SEALANTS, INC. OR EQUAL.
4. INSTALLATION OF VALVE CASING RING SHALL BE PER SPECIFICATIONS.
5. AIR VENT PIPE INSTALLATION SHALL BE AS NEAR AS PRACTICAL TO THE RIGHT-OF-WAY LINE.
6. CONCRETE MANHOLE PENETRATIONS SHALL BE CORE BIT DRILLED. VOID SHALL BE FILLED BY PRESSING SEAL GASKET CORP. PSX RESILIENT CONNECTOR MEETING ASTM C923 OR APPROVED EQUAL.
7. CROSS SECTIONAL AREA OF OPENING TO BE EQUAL TO OR GREATER THAN CROSS SECTIONAL AREA OF AIR VENT PIPE.
8. AIR/VACUUM VALVE SHALL BE INSTALLED IN A MANNER WHICH WILL ALLOW REMOVAL OF ASSEMBLY WITHOUT REMOVAL OF PRECAST CONCRETE LID.

AIR VALVE	GATE VALVE	VENT PIPE (MIN.)	M.H. DIA. (MIN.)
3"	3"	3"	5'
4"	4"	4"	6'
6"	6"	6"	6'
8"	8"	8"	6'
10"	10"	10"	7'
12"	12"	12"	7'



DRAWN BY:
JD Amaro
APPROVED BY:

STANDARD DRAWING:

**3" OR LARGER AIR / VACUUM
VALVE INSTALLATION (TYPE II)**

UPDATED:
4-15-03

SCALE:
N.T.S.

SHEET:
2 OF 2

DRAWING NO.
261