



- | | |
|--|---|
| ① LAY DOWN GATE VALVE WITH HAND WHEEL | ⑨ COMPANION FLANGE (SEE NOTE 6) |
| ② INSULATED FLANGE CONNECTION | ⑩ AIR VENT PIPE |
| ③ CLASS III R.C.P. MANHOLE 60" MIN. I.D. | ⑪ RETURN BEND (FLG X FLG) |
| ④ BOLTED CAST COUPLING ROCKWELL 441 OR EQUAL | ⑫ 5' MIN. (UNDEV. AREAS)
14" MAX. (DEV. AREAS) |
| ⑤ REINFORCED PRECAST CONCRETE LID | ⑬ 90° BEND (FLG X MJ) |
| ⑥ N.B.U. RING AND 32" COVER | ⑭ FLEXIBLE COUPLING |
| ⑦ NO. 16 MESH BRASS CLOTH | ⑮ FLANGED OUTLET PER ANSI B 16.1 |
| ⑧ 1/4" X 1" GALV. STRAPS DRILLED TO 4" D.I. PIPE FILLED WITH CONCRETE (SEE NOTE 2) | |