

MATERIALS LIST

- A. 2" SERVICE CLAMP PER SPL W2.2.1
- B. 2" CORPORATION STOP MALE THREAD INLET BY COMPRESSION OUTLET
- C. 2" AWWA C901 CTS SDR 9 WATER SERVICE PIPE PER SPL W1.5.5
- D. 2" BRASS COUPLING - COMPRESSION TO MALE IPT
- E. 2" BRASS TEE - FEMALE IPT
- F. 2" BRASS CLOSE-NIPPLE
- G. 2" ANGLE METER STOP, FEMALE IPT INLET & OUTLET
- H. 2" BRASS NIPPLE
- I. 2" BRASS ELBOW, FEMALE IPT
- J. 2" LOCKABLE CURB STOP - FEMALE IPT INLET & OUTLET
- K. 2" BRASS COUPLING - SERVICE TUBING TO MALE IPT
- L. 2" METER BOX PER SPL W19.0.0
- M. 2" BRASS UNION (2" X 1-1/2" BRASS ADAPTER- FOR 1-1/2" METER ONLY)
- N. 2" WATER METER, LENGTH 15.25", PURCHASED FROM NBU
- O. 2" SERVICE TUBING (PRIVATE PLUMBING PER CODE)
- P. CUSTOMER CUT-OFF VALVE
- Q. CUSTOMER VALVE BOX AND LID



NEW BRAUNFELS UTILITIES
WATER SYSTEMS ENGINEERING

DRAWN BY:
EWL
APPROVED BY:
A. WILLARD

DRAWING DATE:
2/1/24

STANDARD DRAWING:

STANDARD INSTALLATION DETAIL FOR 1-1/2" & 2"
METER INSTALLATION SHOWING OPTIONAL BYPASS

UPDATED:

SCALE:
N.T.S.

SHEET:
2 OF 2

DRAWING NO.
203