


VERTICAL VALVE

HORIZONTAL VALVE

USE ONLY WHEN SPECIFIED IN DRAWINGS AND WITH NBU STAFF APPROVAL

NOTES:

1. WELD SOCKET 2 1/2" X 2" DEEP TO 1" SCH, 40 CARBON STEEL ROUND STEM EXTENSION, FITTED ON OPERATING NUT. [SCH.80 FOR LENGTHS OVER 10'.]
2. VALVE CASTING SHALL BE 6" DI PIPE WITH BELL OR COLLAR CENTERED OVER VALVE BOOT.
3. NUT AT TOP OF VALVE EXTENSION ROD SHALL BE SQUARE 2" LONG WELDED TO TOP OF ROD.
4. VALVE STEM EXTENSIONS ARE REQUIRED ON ALL VALVES THAT EXCEED 3' DEEP FROM FINISHED GRADE. VALVE EXTENSIONS SHALL BE PLACED SUCH THAT THE EXTENSION NUT IS BETWEEN 12" AND 18" FROM FINISHED GRADE.
5. TRUMBULL VALVE BOX ALIGNMENT DEVICE OR APPROVED EQUAL.



DRAWN BY:
EWL
APPROVED BY:
A. WILLARD
DRAWING DATE:
2/1/24

STANDARD DRAWING:

TYPICAL GATE VALVE

UPDATED:

SCALE:
N.T.S.

SHEET:
1 OF 1

DRAWING NO.

230