


NOTES:

1. HYDRANTS MUST REMAIN UNOBSTRUCTED AT ALL TIMES.
2. A CLEAR SPACE OF 3-FEET MUST BE MAINTAINED AROUND THE CIRCUMFERENCE OF THE FIRE HYDRANT PER SECTION 507 OF THE INTERNATIONAL FIRE CODE EXCEPT AS OTHERWISE REQUIRED OR APPROVED BY THE FIRE CODE OFFICIAL.



DRAWN BY: EWL
APPROVED BY: A. WILLARD
DRAWING DATE: 2/1/24

STANDARD DRAWING: <b>STANDARD FIRE HYDRANT CLEARANCE</b>			
UPDATED:	SCALE: N.T.S.	SHEET: 1 OF 1	DRAWING NO. 242