


NOTES:

1. EXTERIOR SURFACES OF EXPOSED AIR VENT PIPE AND SST SUPPORT PIPE SHALL BE PAINTED WITH RUST-OLEUM ACRYLIC 5225 (SAFETY BLUE), OR EQUAL, PER COATING MANUFACTURER INSTRUCTIONS PRIOR TO INSTALLATION.
2. VENT PIPE SHALL NOT BE INSTALLED IN SIDEWALKS, DRIVEWAYS, OR OTHER TRAFFIC AREAS.
3. 5' MIN. (UNDEVELOPED AREAS), 16" MAX. (DEVELOPED AREAS).
4. THE AIR VALVE AND ASSOCIATED PIPING SHALL BE INSTALLED ABOVE THE HIGHEST ELEVATION OF THE MAIN. AIR VALVE PIPING, FROM THE MAIN TO THE AIR VALVE, SHALL MAINTAIN A CONSTANT RISE WITH NO DIPS.
5. PROVIDE STANDARD 1" METER BOX FOR 1" AIR RELEASE VALVE AND 1.5" METER BOX FOR 2" AIR RELEASE VALVE. STACK AND JOIN BOXES WITH STAINLESS STEEL BOLTS TO PROVIDE ADDITIONAL HEIGHT AS REQUIRED, MAXIMUM 2 BOXES.
6. PIPE SHALL BE EMBEDDED 30" AND TOP OF PIPE SHALL BE A MAX OF 6" FROM THE TOP OF VENT.
7. STRAPS SHALL BE STAINLESS STEEL, STRAP TYPE, CLAMP (TYP.) AND STRAPS EVERY 12".



DRAWN BY:
EWL
APPROVED BY:
A. WILLARD
DRAWING DATE:
2/1/24

STANDARD DRAWING:

**1"-2" AIR RELEASE VALVE
INSTALLATION (TYPE I)**

UPDATED:

SCALE:
N.T.S.

SHEET:
1 OF 2

DRAWING NO.

260