



NOTES:

1. VENT PIPING AND COATINGS PER NBU DETAIL 334.
2. MANHOLE VENT AND SUPPORT PIPING SHALL NOT BE INSTALLED IN SIDEWALK, PARKING AREAS, OR DRIVE AISLES.
3. BOTTOM OF FLANGE SHALL BE MIN. 2'-6" ABOVE GRADE, 3'-6" MAX.
4. VENT PIPING FROM MANHOLE TO 90 DEG. VERTICAL BEND MUST BE LAID TO DRAIN TO THE MANHOLE AT MIN. 2% SLOPE.