

## **NOTES:**

- ALL BOLTS AND HARDWARE TO BE 316 STAINLESS STEEL.
- 2. DUCTILE IRON PIPE AND FITTINGS TO HAVE FACTORY APPLIED PROTECTO 401 EPOXY INTERIOR COATING.
- 3. EXTERIOR OF DUCTILE IRON PIPES AND FITTINGS TO BE FACTORY COATED WITH FACTORY APPLIED PRIME COAT AND SURFACE COAT OF GREEN FUSION BONDED EPOXY.
- 4. CONTRACTOR TO FIELD COAT WITH PENETRATING EPOXY PRE-PRIMER AND HIGH SOLIDS EPOXY SILOXANE PER NBU SPECIFICATION 530.
- 5. PROVIDE ODOR CONTROL CANISTERS ON VENTS WHERE INDICATED ON THE PLANS.
- 6. BOTTOM OF COMPANION FLANGE MUST BE 1' ABOVE THE FEMA BASE FLOOD ELEVATION (BFE), MAXIMUM HEIGHT ABOVE GRADE OF 6'. INSTALL WAGER 1700 VENT VALVE, OR APPROVED EQUAL, WHERE BFE IS MORE THAN 18" ABOVE PROPOSED GRADE.

8 B	5.0	STANDARD DRAWING:  MANHOLE VENT  NON-PAVED AREAS			
MBU	EWL				
	APPROVED BY:				
	A. WILLARD				
NEW BRAUNFELS UTILITIES	DRAWING DATE:	UPDATED:			DRAWING NO.
WATER SYSTEMS ENGINEERING	2/1/24		N.T.S.	1 OF 1	334