


MATERIALS LIST

- A. 2" SERVICE CLAMP PER SPL W2.2.1
- B. 2" CORPORATION STOP MALE THREAD INLET BY COMPRESSION OUTLET
- C. 2" AWWA C901 CTS SDR 9 WATER SERVICE PIPE PER SPL W1.5.5
- D. 2" BRASS COUPLING - COMPRESSION TO MALE IPT
- E. 2" BRASS TEE - FEMALE IPT
- F. 2" BRASS CLOSE-NIPPLE
- G. 2" ANGLE METER STOP, FEMALE IPT X METER FLANGE
- H. 2" BRASS NIPPLE
- I. 2" BRASS ELBOW, FEMALE IPT
- J. 2" LOCKABLE CURB STOP - FEMALE IPT INLET & OUTLET
- K. 2" BRASS COUPLING - SERVICE TUBING TO MALE IPT
- L. 2" METER BOX PER SPL W19.0.0
- M. 2" X 1-1/2" BRASS METER ADAPTER (FOR 1-1/2" METER ONLY - NOT SHOWN)
- N. 2" WATER METER, LENGTH 17", PURCHASED FROM NBU; OR
1.5" WATER METER, LENGTH 13", PURCHASED FROM NBU
- O. 2" SERVICE TUBING (PRIVATE PLUMBING PER CODE)
- P. CUSTOMER CUT-OFF VALVE
- Q. CUSTOMER VALVE BOX AND LID
- R. 2" BALL VALVE, FEMALE IPT X METER FLANGE, WITH HAND LEVER AND PADLOCK WINGS
- S. 2" ANNEALED SEAMLESS TYPE "K" SERVICE TUBING PER ASTM B88

 NEW BRAUNFELS UTILITIES WATER SYSTEMS ENGINEERING	DRAWN BY:	STANDARD DRAWING:				
	APPROVED BY:	STANDARD INSTALLATION DETAIL FOR 1-1/2" & 2" METER INSTALLATION SHOWING BYPASS				
	DRAWING DATE:					SCALE:
EWL	A. WILLARD	8-17-21	2024-07-01	N.T.S.	2 OF 2	203